

PLAN
NTS


NOTES:

1. METERS TO BE PURCHASED FROM CALVERT COUNTY WATER & SEWER DIVISION.
2. ALL CONNECTIONS TO BE COMPRESSION TYPE.
3. WHEN SERVICE LINE IS LARGER THAN THE METER SETTER INLET AND/OR OUTLET, USE COPPER REDUCING FITTING. McDONALD SERIES 4758T OR EQUAL.
4. METER SETTER SHALL BE FURNISHED IN PROPER HEIGHT TO PROVIDE REQUIRED DISTANCE BETWEEN METER TOP AND COVER.
5. METER SETTER SHALL BE A.Y. McDONALD MFG. CO. SETTER FOR 5/8" X 3/4" METER WITH 1-1/2" SPRINKLER LINE OR APPROVED EQUAL.

NOTE:

THIS DETAIL APPLIES
TO ALL PROJECTS
APPROVED AFTER
JULY 1, 2013

REVISIONS:	CALVERT COUNTY	STANDARD DETAILS	
5-7-08	DEPARTMENT OF PUBLIC WORKS-BUREAU OF UTILITIES	METER SETTING	<u>W</u>
7-1-13	APPROVED: BUREAU CHIEF	FOR HOUSES WITH	1.42
	DATE: JULY 1, 2013	SPRINKLER SYSTEMS	SHEET 1 OF 2



ELEVATION
NTS

NOTE:
THIS DETAIL APPLIES
TO ALL PROJECTS
APPROVED AFTER
JULY 1, 2013

REVISIONS:	CALVERT COUNTY	STANDARD DETAILS	W
5-7-08			
7-1-13	DEPARTMENT OF PUBLIC WORKS-BUREAU OF UTILITIES	METER SETTING	1.42
	APPROVED: <i>R. G. Taylor</i>	FOR HOUSES WITH	
	BUREAU CHIEF	SPRINKLER	
	DATE: JULY 1, 2013	SYSTEMS	SHEET 2 OF 2