



NOTES:

1. FOR THIS MANHOLE, THE INTERIOR SURFACE SHALL BE COATED WITH A TWO COAT EPOXY PAINT SYSTEM - TNEMEC SERIES 61 OR APPROVED EQUAL. EACH COAT SHALL BE A MINIMUM 5.0 DRY MILS.
2. IN THE CASE OF A FORCE MAIN CONNECTION TO THE MANHOLE, THE NEXT MANHOLE DOWNSTREAM MUST BE COATED IN ACCORDANCE WITH NOTE NUMBER 1 ABOVE.

NOTE:

THIS DETAIL APPLIES TO ALL PROJECTS APPROVED AFTER MAY 5, 2008

REVISIONS:	CALVERT COUNTY DEPARTMENT OF PUBLIC WORKS - BUREAU OF UTILITIES APPROVED:  BUREAU CHIEF DATE: DECEMBER 15, 2004	STANDARD DETAILS	<u>S</u> 1.17
5-1-08		SERVICE LATERAL OR FORCE MAIN CONNECTION TO MANHOLE	