



NOTES:

1. Maintain 3'-6" min. cover over pressure sewer.
2. Concrete Block: Rest on undisturbed earth or firm subgrade
3. Roofing felt shall conform to ASTM D250, Type 1.
4. Service line - PVC - Schedule 80 with threaded joint.
5. Service line - PVC - SDR 21 Gasket joints.
6. Valve Boxes to say "SEWER" on lid covers.
7. All gate valves to have 2" sq. operating nut.

Note:
This detail applies to all projects approved after May 5, 2008

REVISIONS:	CALVERT COUNTY	STANDARD DETAILS	$\frac{S}{1.30}$
5-1-08	DEPARTMENT OF PUBLIC WORKS-BUREAU OF UTILITIES	LPS- SERVICE CONNECTION ASSEMBLY	
	APPROVED:  BUREAU CHIEF		
	DATE: DECEMBER 15, 2004		