



Notes:

1. Flushing connection to be located where shown on drawings.
2. Concrete block to rest on undisturbed, firm subgrade.
3. Line valves:
 - a. 2" gate valves with FNPT ends in lines 2" and smaller
 - b. plug valves with MJ ends in lines 3" and larger.
 - c. valve operating nuts to be 2"x2", square type only
4. Max. spacing 400ft.
5. All roadway box lids to say "SEWER".

Note:

This detail applies to all projects approved after May 5, 2008

REVISIONS:	CALVERT COUNTY DEPARTMENT OF PUBLIC WORKS—BUREAU OF UTILITIES APPROVED:  BUREAU CHIEF DATE: <u>DECEMBER 15, 2004</u>	STANDARD DETAILS LPS IN-LINE CLEANOUT	<u>S</u> 1.31
5-1-08			