



NOTES:

1. Flushing connection to be located where shown on drawings.
2. Concrete block to rest on undisturbed, firm subgrade.
3. Line valves:
 - a. 2"– Gate valve with female threaded ends
 - b. 3" and larger– Plug Valves with MJ ends
 - c. valve operating nuts to be 2"x 2", square type only.
4. All lids to be marked "SEWER".

Note:

This detail applies to all projects approved after May 5, 2008

REVISIONS:	CALVERT COUNTY	STANDARD DETAILS	
5-1-08	DEPARTMENT OF PUBLIC WORKS—BUREAU OF UTILITIES	LPS TERMINAL CLEANOUT	S 1.32
	APPROVED:		
	DATE: DECEMBER 15, 2004		